## Product data sheet Characteristics

# HDL26015

# PowerPact H Circuit Breaker, Therm Magn, 15A, 2P, 600V, 14kA

Product availability: Stock - Normally stocked in distribution facility





Price\*: 870.00 USD



### Main

Product or component type	Circuit breaker	
Range of product	PowerPact H	
Trip Unit Type	Thermal-magnetic	
Breaking capacity code	D	

#### Complementary

Street & FEE		
10:0		
Main		
Product or component type	Circuit breaker	
Range of product	PowerPact H	
Trip Unit Type	Thermal-magnetic	
Breaking capacity code	D	
Complementary		
Complementary Line Rated Current	15 A	
Number of Poles	2P	
Interrupt Rating	18 kA at 480 V AC	
menupi rating	25 kA at 240 V AC	
	14 kA at 600 V AC	
	20 kA at 250 V DC	
System Voltage	250 V DC 600 V AC	
Continuous current rating	80 %	
Mounting mode	Unit mount	
Electrical connection	Lugs load	
	Lugs line	
Wire Gauge	AWG 14AWG 3/0 (aluminium/copper)	
Magnetic hold current	350 A	
Magnetic tripping current	750 A	
Height	6.4 in	
Width	2.74 in	
Depth	4.36 in	
Environment		
Product certifications	CE	

### Environment

D	roduct certifications	CE
М	roduci cerinications	$\cup$ E

cs	Α	
IEC	)	
UL	listed	

Ambient air temperature for operation	104 °F (40 °C)
Ambient all temperature for operation	107 1 (70 0)

## Ordering and shipping details

Category	01110 - HD,JD UNIT MT BREAKER/SWITCH
Discount Schedule	DE2
GTIN	00785901458869
Nbr. of units in pkg.	1
Package weight(Lbs)	3.030000000000002
Returnability	Υ
Country of origin	MX

## Offer Sustainability

Sustainable offer status	Green Premium product
RoHS (date code: YYWW)	Compliant - since 0832 - Schneider Electric declaration of conformity
	Schneider Electric declaration of conformity
REACh	Reference not containing SVHC above the threshold
	Reference not containing SVHC above the threshold
Product environmental profile	Available
Product end of life instructions	Need no specific recycling operations
California proposition 65	WARNING: This product can expose you to chemicals including:
Substance 1	DINP, which is known to the State of California to cause cancer, and
Substance 2	DIDP, which is known to the State of California to cause Birth Defects or other reproductive harm.
More information	For more information go to www.p65warnings.ca.gov

## Contractual warranty

Mariana da ana da al	40 months
Warranty period	18 months